

**Department of Transportation
Olympia, Washington 98504**

April 28, 2004

ATTENTION: All Bidders and Planholders

**I 90
SUNSET WAY I/C RETAINING WALL 16
IM-0901(429)**

Addendum No. 5

The Special Provisions, Plans, and Proposal for this project are amended as follows:

Special Provisions

1. On page 80, lines 19 through 23 are deleted and replaced with the following:
 - C. The steel soldier piles and attachments shall be shop painted after fabrication to the limits shown in the Plans with one coat of inorganic zinc primer. Application of the one coat of primer shall be in accordance with Section 6-07. The welded shear studs may be attached before or after painting. Paint damaged by welding shear studs in place does not require repair.
2. On page 98, lines 23 through 28 are deleted and replaced with the following:

A high-flow sand filter unit shall have a manufacturer's hydraulic capacity of 4546 liter per minute (lpm) with an operational flow rate of 2728 lpm. The high-flow sand filter feed water pump shall have minimum capability of 6819 lpm at 2.81 kilogram per square centimeter (ksc).

Plans

1. Plan sheets 1, 3, and 4 are revised as shaded and noted on the attached sheets.
2. Plan sheets 32, 33, 34, 35, 36, and 37 are replacement sheets.
3. New Plan sheets 37A, and 37B are to be inserted after Plan sheet 37.
4. New Plan sheet 50A is to be inserted after Plan Sheet 50.

Proposal

1. On page 2:
 - Item No. 15 is deleted.
 - Item No's. 14, 16, 17, 18, and 19, the PLAN QUANTITY is revised.
2. On page 6: Item No's. 61, and 62 are added.

Bidders shall furnish the Secretary of Transportation with evidence of receipt of this Addendum. This Addendum will be incorporated in the contract when awarded and when formally executed.

Harold Peterfeso, P.E.
State Design Engineer

Attachment:

Sheets 1, 3, 4, 32, 33, 34, 35, 36, 37, 37A, 37B, and 50A of the Plans (Rev. 4-26-04).

Pages 2, and 6 of the Proposal (Rev. 4-26-04).

ADDENDUM NO. 5
I 90
SUNSET WAY I/C RETAINING WALL 16
IM-0901(429)